

# ADDENDUM #4 TO THE CONTRACT DOCUMENTS



## I. GENERAL

- A. This Addendum to the Contract Documents shall be considered a part of the Contract Documents as if originally written and included in same. Where changes in materials or workmanship are indicated herein, these changes shall take precedence over the original Contract Documents. The Contractor is responsible for notifying all subcontractors of the changes in this Addendum which may affect their work.

## II. CHANGES TO THE DRAWINGS

- A. A security cage assembly shall be installed at each HVAC compressor unit. Insert onto all four (4) of the A1 drawing sheets this note: "NOTE: At each HVAC compressor unit, provide one (1) security cage assembly. Basis-of-design security cage assembly: Zelvoro adjustable height (up to 44 inches) and adjustable width (up to 46") factory-finished steel cage with anti-theft screws. Provide two inches of clearance between the HVAC equipment and the security cage at the top and the four sides of the HVAC equipment. Anchor each security cage to the concrete platform. Submit security cage product information as per Specification Section 01 33 00."
1. Insert this note on Sheet A1 for 1440 & 1442 Mansfield Avenue.
  2. Insert this note on Sheet A1 for 1444 & 1446 Mansfield Avenue.
  3. Insert this note on Sheet A1 for 1234 & 1236 Marshall Drive.
  4. Insert this note on Sheet A1 for 6100A & 6100B Fifth Avenue.

**END OF ADDENDUM #4 NARRATIVE. There are no attachments to this Addendum.**

**All addenda must be acknowledged on the Bid Form.**